



INTERLOCKS USING NC TERMINALS OF CONTACTOR  
 LIVE NC FOR V1 REST OFF WHEN V1 ON  
 NUET NC FOR V2 REST OFF WHEN V2 ON

SIGMA PROCESS CONTROL TECHNOLOGIES PVT LTD		
#2456, 17TH 'E' CROSS, 9TH MAIN, II STAGE, BANASHANKARI, BANGALORE 560 070 PH:6641586/648863		
Title SOLENOIDS OF ULTI-HIVAC		
Size B	Document Number 98SPCT22.SCH	Rev 00
Date: Wednesday, August 20, 2003	Sheet 1	of 1